CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL

FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7170-0554:150 Page 1 of 3

CATEGORY: Control Unit (High-Rise)

LISTEE: Johnson Controls, 507 E Michigan St, Milwaukee, WI 53202-5211

Contact: James D. Kinney (414) 524-4358 Fax (414) 276-5979

DESIGN: Model IFC-3030, IFC-3030E fire alarm control units. Local, auxiliary, remote station (PPU),

proprietary (PPU), central station (PPU), automatic, manual, waterflow and sprinkler supervisory services. Refer to listee's data sheet for detailed product description and

operational considerations. System components:

AA-30/-100/-120 Amplifiers

ACM-8R/-16AT/-24AT/-32A/-48A Annunciator Control Modules ACPS-2406 Addressable/Charger Power Supply

ACT-1/-2 Audio Coupling Transformer
AEM-16AT/-24AT/-32A/-48A Annunciator Expander Modules
AFM-16A/-16AT/-32A Annunciator Fixed Modules

JAKS-1B Annunciator Key Switch
AMG-1/-E Audio Message Generator
AMPS-24 Addressable Main Power Supply

APS-6R Auxiliary Power Supply ARM-4 Auxiliary Relay Module

BGRA-SCS, BGRB-SCS, Smoke Control Enclosures for SCS Modules CEF-SCS, RSA-SCS, RSB-SCS, Smoke Control Enclosures for SCS Modules Smoke Control Enclosures for SCS Modules Smoke Control Enclosures for SCS Modules

Chassis

BB-100/-200 Battery Box
BMP-1 Blank Module
BP-4 Battery Panel

BX-501 Intelligent Detector/Sensor Base

B-501J Intelligent Base

B-210LPJ Intelligent Detector Base

CAB-4 Series Enclosure
CHG-120 Battery Charger

CHS-4L/-4MB/-4N/-6/-M3/-PS

CHS-M3 Chassis JCPU-3030D/JCPU-3030ND CPU Board

CRE-4 Control Relay Expander
CRM-4RK Control Relay Module
CRT-2 Display Terminal
DCM-4RK Dual Channel Module

DP-1B Blank Panel

DP-DISP Display Dress Panel DPDW-1B, DPSW-1B, XPDP, Dress Panels VP-2B Dress Panels

DPI-232 Direct Panel Interface

Listing No. 7170-0554:150 Page 2 of 3

FCPS-24 Field Charger/Power Supply FFT-7/-7S Fire Fighter's Telephones **FHS** Fireman's Handset FPJ Fireman's Phone Jack Indicating Control Expander ICE-4 Indicating Circuit Module ICM-4RK IZE-A Initiating Zone Expander IZM-8RK Initiating Zone Module LCD-80 Liquid Crystal Display Module

LCM-320 Loop Control Module
LDM-32/-E32/-R32 Lamp Driver Module
LEM-320 Loop Expander Module

MP-1B Blank Panel

MPS-24B Power Supply Module

JBG-12 Series Addressable Manual Pull Station
JNCA Network Control Annunciator
NCM-W/-F Network Control Module
N-ELR End of Line Resistors

JCI-LBB/-LBBR/-BB-25/-BB-17 Battery Box JPRN-5 Printer

R-120/-2.2K/-27K/-470/-47K End of Line Resistors
RA-400/-400Z Remote Annunciators
RKS-S Remote Security Keyswitch
RPJ-1 Remote Paging Jack

RPT-W/-F/-485W/-485WF Repeater

RM-1/-1SA

SCS-8

SCE-8

STS-1

TM-4

Remote Microphone

Smoke Control Station

Smoke Control Expander

Security Tamper Switch

Transmitter Module

TR-A4/-B4/-C4/-D4
UDACT
UZC-256
Universal DACT
Universal Zone Coder
VCE-4
Voice Control Expander
VCM-4RK
Voice Control Module
VS4095
Keltron Remote Printer

XP5-C/-M Transponder

XPC-8 Transponder Control Module

XPIQ Transponder Quad Intelligent Audio Module

XPM-8/-8L Transponder Monitor Modules
XPP-1 Transponder Processor
XPR-8 Transponder Relay Module

INSTALLATION:

In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

Listing No. 7170-0554:150

Page 3 of 3

01-08-04

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as fire alarm control units suitable for high rise applications for use with separately

listed compatible initiating and indicating devices. Refer to listee's Installation Instructions

Manual for details.

This control unit can generate a distinctive three-pulse Temporal Pattern Fire Alarm

Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1999 Edition.

NOTE: For Fire Alarm Verification Feature (delay of fire alarm signal), the maximum

Retard/Reset/Restart period shall not exceed 30 seconds.

XLF: 7170-0028:223



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: JANUARY 8, 2004 Listing Expires June 30, 2004

Authorized By: **DIANE K. AREND**, Senior Deputy

Program Manager